

S757

GLUTICIDE 15

A microbiocide for controlling slime-forming bacteria, sulfate-reducing bacteria and algae in air washers and recirculating cooling water systems; service water and auxiliary systems; heat transfer systems.

GUARANTEE: Glutaraldehyde 15% By Weight

REGISTRATION NO: 31043 Pest Control Products Act

USES:

- AIR WASHERS AND INDUSTRIAL SCRUBBING SYSTEMS, RECIRCULATING COOLING AND PROCESS WATER SYSTEMS
- INTERMITTENT (SLUG DOSE) METHOD
- CONTINUOUS FEED SYSTEM
- PASTEURIZER COOLING WATER SYSTEM
- SERVICE WATER AND AUXILIARY SYSTEMS
- HEAT TRANSFER SYSTEMS (Evaporative Condensers, Hydrostatic Sterilizers and Retorts, and Pasteurizers and Warmers)

Initial Dose: when the system is noticeably fouled, add 333 mL - 1333 mL of Gluticide 15 per 1000 L of water in the system. Repeat until control is achieved.

Subsequent Dose: when microbial control is evident, add 100 mL – 333 mL of Gluticide 15 per 1000 L of water in the system weekly or as needed to maintain control. Badly fouled systems must be cleaned before treatment begins.

Avoid contamination of food in the application of product. It should be added to the closed recirculating system at a convenient point such as a basin area, sump area, other reservoir or collection area from which the treated water will be circulating uniformly throughout the system.

FOR COMMERCIAL USE ONLY

March 12, 2014



Intertek